

FIRE



Ref. No.

Dated 30/4/24.....

TEST & WARRANTY CERTIFICATE

1. **PARTY'S NAME & ADDRESS** : DATTA PUBLIC SCHOOL , HISAR

2. **ITEM & QUANTITY** : For Fire Extn.
ABC 6KG - 2 NOS (NEW)

3. **B.I.S. SPECIFICATION** : IS 15683;2006

4. **HYDRO TEST** : TESTTED TO 35 Kgf/ Cm²

5. **OUR SERIAL NO** : 1 TO 2

6. **TYPE** : ABC Type Constant Pressure
(Mono Ammonium Phosphate 60-70 %)

WARRANTY

The above- mentioned goods are warranted against defect in material and workmanship under normal use. The warranty is limited to a period of SIXTY MONTHS FROM THE DATE OF SUPPLY whichever Earlier is. The company's obligation shall be limited to rectifying, repairing or replace defective parts Ex- Factory, provided the purchase has given immediate written notice upon the discovery of such defect. The company will be automatically relieved of its obligation in case the unit is opened or any changes/ repairs are made without its prior approval within the guarantee period. This warranty accident resulting the defective and faulty workmanship.



INDIAN SECURITY & FIRE SAFETY

DSS-194, Pocket-A, Sec. 14, HISAR - 125001

Office : 92533-92596, M. 92151-92596

Mail : indiansfsafety@gmail.com | web. : www.indiansfsafety.com